

## MARKETING BULLETIN

Reference Number	2024-102
Publish Date	2024-Sept-10
Revision Date	2024-Sept-10
Author	Mikael Hildell

## **Title**

Subject	SDU 410 - Cyber Security Compliant	
Products Covered	All versions of the SDU 410 Safety Shutdown Unit with a software version of 1.50 or higher.	
	P/N 1006451 1100630 1100232	Product SDU 410 Safety Shutdown Unit

Description	For Cyber Security reasons, the Ethernet interface (COM3) of the SDU 410 is disabled by default.  This ensures that upon delivery, the COM3 interface is inactive, requiring no additional configuration or inspection from customers to meet Cyber Security standards.		
Customer Impact	If the Ethernet interface is not connected or not in use, no impact.  If the Ethernet interface is in use, consider one of the following alternatives		
	Ethernet function used	Alternative	
	SDU 410 Web Configuration	Configure SDU 410 using 1. A DCU 410E / DCU 210E 2. A Modbus RTU client	
	3rd party Modbus TCP integration	Use Modbus RTU / COM2	
	If the installation still requires Ethernet connectivity on the SDU 410, discuss options with the relevant classification society.		
Validity	Until otherwise noted.		
Distribution	All contracted distributors. Selected customers.		